

Attestation of Compliance

No. N5A 049606 0015 Rev. 00

Holder of Certificate: **Vossloh-Schwabe
Deutschland GmbH**
Stuttgarter Straße 61/1
73614 Schorndorf
GERMANY

Product: **LED Module
(LED Module)**

This Attestation of Compliance is issued on a voluntary basis and confirms the compliance with the listed electrical safety standards for electrical equipment below 50V AC or 75 V DC, which is below the voltage limits of the Low Voltage Directive 2014/35/EU. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 077-1247021-100

Date, 2022-07-11



(Harry Kwon)

Attestation of Compliance

No. N5A 049606 0015 Rev. 00

Model(s): VCA2-122, VCA2-123, VCA2-124, VCA2-126,
VCA2-128, VCA2-1211, VCA2-1213

Brand: VS

Parameters:

Rated voltage (VF): 35.7 V (Model VCA2-122),
36.6 V (Model VCA2-123),
35.3 V (Model VCA2-124),
34.6 V (Model VCA2-126),
35.0 V (Model VCA2-128),
35.9 V (Model VCA2-1211),
36.3 V (Model VCA2-1213)

Rated current (If): 350 mA (Model VCA2-122),
500 mA (Model VCA2-123),
750 mA (Model VCA2-124),
700 mA (Model VCA2-126),
1050 mA (Model VCA2-128),
1700 mA (Model VCA2-1211),
2100 mA (Model VCA2-1213)

Protection class: III
Remark: When installing, all requirements of
below mentioned standard should be fulfilled.

**Tested
according to:** EN IEC 62031:2020
EN 62471:2008
IEC TR 62778:2014