

# CERTIFICATE

Issued to:  
Applicant:  
**Vossloh-Schwabe Deutschland GmbH**  
**Hohe Steinert 8**  
**58509 Lüdenscheid, Germany**

Licensee:  
**Vossloh-Schwabe Deutschland GmbH**  
**Wasenstrasse 25**  
**73660 Urbach, Germany**

Product : Electronic controlgear for LED modules  
Trade name(s) : VS LIGHTING SOLUTIONS  
Type(s)/model(s) : EDXe 112/12.033

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 61347-1:2015, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 3409202

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 24 November 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 81-121436

DEKRA Certification B.V.



**B.T.M. Holtus**  
Managing Director



**H.R.M. Barends**  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Electronic controlgear for LED modules
Trade name(s)	: VS LIGHTING SOLUTIONS
Type(s)/model(s)	: EDXe 112/12.033
Primary voltage	: 220-240 V a.c.
Rated frequency	: 50-60 Hz
Primary current	: 0,12 A
Output voltage	: 12 V
Output power	: 12 W
Type of load	: LED modules, power LED
Classification	: Independent IP20, Class II

**TESTS****Test requirements**

EN 61347-2-13:2014  
EN 61347-2-13:2014/A1:2017  
EN 61347-1:2015  
EN 62384:2006  
EN 62384:2006/A1:2009

**Test result**

The test results are laid down in DEKRA test file 350033600.

**Additional information**

For specific Model/Type electrical rating refer to following page.

DEKRA test report No. 3500336.480 and 3500336.481 are laid down in DEKRA test file 350033600 and they contain test results.

DEKRA test report No. 3500336.480 contains critical component list.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**  
