Ref. Certif. No.

NO124562

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Electronic Controlgear for LED

Vossloh-Schwabe Deutschland GmbH

Stuttgarter Straße 61/1 Schorndorf 73614

Germany

Vossloh-Schwabe Deutschland GmbH

Stuttgarter Straße 61/1 Schorndorf 73614

Germany

PRI: max. 0.46 A, 220-240 V~, 50/60 Hz, PF > 0.95 SEC: 7.8-60.2 W, max. 1.40 A, 9-52 Vd.c. (under load),

max. 60 Vd.c. (no-load)



ECXd 700.635, ECXd 1050.636, ECXd 1400.637

Independent type with terminal cover incl. strain relief, Class II; Built-in type without terminal cover, SELV, constant current output, thermal protected 110 °C, ta: 50 °C, tc: 85 °C / 90 °C

☐ Additional Information on page 2

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

REP001970

This CB Test Certificate is issued by the National Certification Body

Nemko

Philip Pedersens vei 11, NO-1366 Lysaker, Norway

Date: 09-11-2022

Sweet Yuan

Signature: Sweet Yuan

**Certification Department**