



Ref. Certif. No.

SG PSB-LE-05901

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules Electronic converter of LED
Name and address of the applicant	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1 73614 Schorndorf GERMANY
Name and address of the manufacturer	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1, 73614 Schorndorf, GERMANY
Name and address of the factory	Zhejiang Klite Lighting Holdings Co.,Ltd No.12 Tingchao Road,, Jianshan New District,, 314415 Haining City, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	Rated voltage: 120-277V~ Rated frequency: 50/60Hz Rated output: See model list Type of output: Constant voltage type tc: See model list ta: -20~45°C Method of installation: Independent Degree of protection: IP20 Protection class: Class II Protection against electric shock: SELV
Model/type Ref.	Type EDXe 120/24.075 (Ref.- No.187036), Type EDXe 140/24.076 (Ref.- No.187037), Type EDXe 160/24.077 (Ref.- No.187038), Type EDXe 160/24.077 (Ref.-No.187524), Type EDXe 1100/24.078 (Ref.- No.187039)
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	087-2401535-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0040 Rev. 00

Date, 2024-06-14

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-LE-05901

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Model list:

Model	P _{rated} (W)	Output Voltage (Vd.c.)	U _{out} (Vd.c.)	I _{rated} (A)	tc(°C)
Type EDXe 120/24.075 (Ref.- No.187036)	20	24	31	Max.0.833	75
Type EDXe 140/24.076 (Ref.- No.187037)	40	24	31	Max.1.67	85
Type EDXe 160/24.077 (Ref.- No.187038)	60	24	31	Max.2.5	85
Type EDXe 160/24.077 (Ref.- No.187524)	60	24	31	Max.2.5	85
Type EDXe 1100/24.078 (Ref.- No.187039)	100	24	25	Max.4	85

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0040 Rev. 00

Date, 2024-06-14

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore